OHA - Drinking Water Services - Surface Water Quality Data Form Polk County: Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems Month/Year: 3/2021 System Name: **Camp Tapawingo** ID#: 41 91259 WTP: TP-Α 12 AM 4 AM 8 AM NOON 4 PM 8 PM Day Highest Reading of the day 1 [NTU] [NTU] [NTU] [NTU] [NTU] [NTU] [NTU] 1 2 0.71 3 4 5 6 7 8 9 10 11 12 13 14 15 16 0.74 17 18 19 20 21 22 23 24 25 26 27 28 29 0.94 30 31 Slow Sand/Membrane/DE Filtration/Unfiltered Monthly Summary (Answer Yes or No) CT's met everyday? (see All Cl2 residual at entry point 95% of daily turbidity readings ≤ 1 NTU? ² Yes back) ≥ 0.2 mg/l? All daily turbidity readings ≤ 5 NTU? Yes Yes Yes Notes: PRINTED NAME: Brad Schmidt

PHONE #: (503) 787-3828

CERT #: N/A

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : A

Disinfection Giardia Log

System Name: Camp Tapawingo ID#: 41 91259 Month/Year: 3/2021 Inactiv: 1.0

	I Minimum	1			1	1		
Date / Time	Minimum CI ₂ Residual at 1st User (C)	Contact Time (T)	Actual CT	Temp	рН	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L	[minutes]	CXT	[° C]		formula	Yes / No	[GPM]
1		49						
2/9.23am	3	49	147.0	8.2	8.20	84.5	Yes	
3		49						
4		49						
5		49						
6		49						
7		49						
8		49						
9		49						
10		49						
11		49						
12		49						
13		49						
14		49						
15		49						
16/9.17am	2	49	98.0	7.1	8.40	87.2	Yes	
17		49						
18		49						
19		49						
20		49						
21		49						
22		49						
23		49						
24		49						
25		49						
26		49						
27		49						
28		49						
29/8.35am	2.2	49	107.8	7.6	8.50	89.5	Yes	
30		49						
31		49						